

# CERTIFICATE OF ACCREDITATION

## The ANSI National Accreditation Board

Hereby attests that

# **Doble Engineering Company**

11727 South Sam Houston Parkway West, Suite D Houston, Texas 77031

Fulfills the requirements of

ISO/IEC 17025:2017

In the field of

## **TESTING**

This certificate is valid only when accompanied by a current scope of accreditation document. The current scope of accreditation can be verified at <a href="www.anab.org">www.anab.org</a>.

Jason Stine, Vice President

Expiry Date: 05 December 2026 Certificate Number: AT-2637.03





### **SCOPE OF ACCREDITATION TO ISO/IEC 17025:2017**

## **Doble Engineering Company**

11727 South Sam Houston Parkway West, Suite D Houston, Texas 77031

Vernon Glover 713-741-7148

### **TESTING**

Valid to: December 5, 2026 Certificate Number: AT-2637.03

#### Chemical

Version 008 Issued: January 17, 2025


Specific Tests and/or Properties Measured	Specification, Standard, Method, or Test Technique	Items, Materials or Product Tested	Key Equipment or Technology
Dissolved Gas Analysis	ASTM D3612, Method C, IEC 60567	Dielectric Fluid	Gas Chromatography
Moisture	ASTM D1533/IEC 60814	Dielectric Fluid	Karl Fischer Automatic Titration
Neutralization Number	ASTM D974	Dielectric Fluid	Titration
Dielectric Breakdown	ASTM D1816	Dielectric Fluid	Oil Breakdown Voltage Tester
Dielectric Breakdown	ASTM D877	Dielectric Fluid	Oil Breakdown Voltage Tester
Power Factor	ASTM D924/IEC 60247	Dielectric Fluid	Oil Tester
Interfacial Tension	ASTM D971	Dielectric Fluid	Automatic / Manual Force Tensiometer
Specific Gravity	ASTM D4052	Dielectric Fluid	Automatic Densitometer
Color of Petroleum Products	ASTM D1500	Dielectric Fluid	Visual Color Comparator Instrument
Visual Examination	ASTM D1524	Dielectric Fluid	Visual
Corrosive Sulfur	ASTM D1275	Dielectric Fluid	Copper/Silver strip Polishing/Tarnishing





#### Note:

1. This scope is formatted as part of a single document including Certificate of Accreditation No. AT-2637.03.



Version 008 Issued: January 17, 2025

