Data Sheet

High performance inductive PD sensors





Specifications

Bandwidth Max Sensitivity (V_{out} / I_{in} @5MHz) Load Impedance Hole dimension Operating temperature 1MHz ÷ 80MHz 19mV/mA 50Ω Φ 78mm -20°C +70°C

HFCT 78mm

Techimp High Frequency Current Transformer 78mm Clamp is an inductive sensor for Partial Discharge detection. It is suitable for on/ off line PD tests on many electrical systems such as cables, transformers, rotating machine, etc...

The main advantage of the HFCT 78mm Clamp is the easy installation on the ground connection of the electrical system under test without the need of disconnecting it.

A coaxial BNC connector is available to connect the HFCT 78mm Clamp to any Techimp PD acquisition unit by means of a 50Ω coaxial cable.

The arrow on the enclosure indicates the polarity of the output voltage (Vout) in relation to the input current (Iin) direction: when the sensor is installed with the arrow directed to ground, the detected voltage signal (Vout) has the same phase as the input current (Iin).


Benefits

- Maintenance free
- High sensitivity and reliability
- Robust and easy to use
- Safety



HFCT 78mm

Frequency Response



Several different sensors are available, fully compatible with Techimp Global Diagnostic platform. They can be freely combined at customer needs provided they can be applied for the specific application.





TECHIMP - ALTANOVA GROUP Via Toscana 11, 40069 Zola Predosa (Bo) - Italy T +39 051 199 86 050 Email sales@altanova-group.com



ISA - ALTANOVA GROUP Via Prati Bassi 22, 21020 Taino (Va) - Italy T +39 0331 95 60 81 Email isa@altanova-group.com



intelliSAW - ALTANOVA GROUP 100 Burtt Rd Andover, MA 01810, USA T +1 978-409-1534 Email contact@intellisaw.com

The product and the information contained herein may be changed at any time without prior notification. This document nor any parts thereof may not be reproduced or transmitted in any form either electronically or mechanically, including photocopying and recording, without the express written consent of Techimp - Altanova Group Srl